

DECLARATIE DE CONFORMITATE/DECLARATION OF CONFORMITY

Nr./No. DoC_P74000_5059340582436_3_RO

1. **Cod unic de identificare al produsului-tip/Unique identification code of the product-type:**
BATERII CU MONOCOMANDA/SINGLE LEVER FAUCETS
2. **Tipul, lotul sau numarul de serie sau orice alt element care permite identificarea produsului** pentru constructii/Type, batch or serial number or any other element allowing identification of the construction product: numarul lotului si codul EAN sunt inscriptionate pe ambalaj conform Anexei I/ the batch number and the EAN code are written on the package according Annex I
3. **Utilizarea sau utilizarile preconizate ale produsului pentru constructii/Intended use or uses of the construction product:**
- se utilizeaza in instalatii sanitare de alimentare cu apa potabila rece si apa calda de consum/are used in sanitary installations for cold potable water supply and hot water for consumption.
4. **Numele, denumirea sociala sau marca inregistrata si adresa de contact a fabricantului/Name,** registered trade name or registered trademark and contact address of the manufacturer:
Kingfisher International Products B.V.
Rapenburgerstraat 175E, 1011 VM Amsterdam, The Netherlands
5. **Numele si adresa de contact a reprezentantului autorizat/Name and contact address of the authorised representative (where applicable):** -
6. **Conformitatea este demonstrata avand ca referinta/The conformity is demonstrated with the reference:**

AGREMENTUL TEHNIC IN CONSTRUCTII NR. 017-05/3967-2023

7. **Performantele produselor/Products performances:**

Caracteristici/Characteristics:	Standardul de incercari/Test Standard	Nivel de referinta/ Reference level	Valori declarate (rezultate incercari)/ Declared values (test results)
Baterie cu monocomanda tip/single lever faucet type "GoodHome" model ETEL (C10010840, EAN 5059340582436)			
Verificarea etanseitatii/ Tightness check (4 bar, 60 sec.)	SR EN 817:2008	fara scapari de fluid fara ruperi de material sau deformari, in zonele de imbinare/ without fluid leaks without material ruptures or deformations, in the joint areas	corespunde/ corresponds
Verificarea rezistentei la presiune/Checking the pressure resistance (16 bar, 60 sec.)	SR EN 817:2008	fara scapari de fluid fara ruperi de material sau deformari, in zonele de imbinare fara scurgeri/ without fluid leaks without material ruptures or deformations, in the joint areas without leaks	corespunde/ corresponds
Verificarea aspectului/ Checking the appearance	ILT 12	fara asperitati, neregularitati inainte si dupa testarea la etanseitate/no roughness, irregularities before and after the tightness test	corespunde/ corresponds

8. Denumirea si adresa laboratorului care a efectuat incercarile/Name and identification of the laboratory which performed the tests:

Laboratorul INSIST - UTCB Bucuresti, B-dul Pache Protopopescu nr. 66, sector 2.

Aceasta declaratie de conformitate este emisa pe raspunderea exclusiva a fabricantului identificat la punctul 4./This declaration of conformity is issued under the sole responsibility of the manufacturer identified in point 4.

Semnata pentru si in numele fabricantului de catre/Signed for and on behalf of the manufacturer by:



David Awe

Group Quality Director

Paddington, 27/09/2023

Anexa/Annex I

EAN 3663602662945
EAN 3663602662242
EAN 3663602662228
EAN 3663602662235
EAN 3663602662273
EAN 3663602664963
EAN 3663602481829
EAN 3663602481843
EAN 3663602481874
EAN 5059340582436